


Whole Foods Market Improves Energy Efficiency in New Construction

Whole Foods Market partnered with the U.S. Department of Energy (DOE) to develop and implement solutions to reduce annual energy consumption in new stores by at least 50% versus requirements set by ASHRAE/ANSI/IESNA Standard 90.1-2004¹ as part of DOE’s Commercial Building Partnership (CBP) program.² The National Renewable Energy Laboratory (NREL) provided technical expertise.

The new Whole Foods Market store in North Raleigh, North Carolina, opened in March 2011. The store is a single-story, 40,000-ft² building, selling packaged food, fresh produce, general merchandise items, and prepared food. Whole Foods Market engineers and NREL staff brought new energy efficiency measure (EEM) ideas to the table starting with DOE Advanced Energy Design Guide and Advanced Energy Retrofit Guide recommendations.³ Model-based expectations of energy savings using EnergyPlus⁴ are shown in the “Expected Energy Cost Reductions” graph below.

From May 2011 through April 2012, total savings based on measurements from the store were 32% versus ASHRAE 90.1-2004 despite significant problems with the store’s refrigeration condensers. Another challenge to reaching 50% savings was the large proportion of energy use going to loads such as cooking and refrigeration (about 50% of the energy consumed in a typical new Whole Foods Market), which were outside the purview of ASHRAE 90.1-2004. There has historically been less focus on saving energy in those end uses compared to code-regulated items such as envelope, lighting, and heating, ventilating, and air conditioning (HVAC) systems. The CBP team also had to craft baseline scenarios for those end uses analogous to ASHRAE 90.1-2004 to calculate energy savings.

Expected Energy Cost Reductions



The commercial kitchen at the Raleigh Whole Foods Market was a prime target for efficiency improvement.

NREL/PIX 18611

Project Type	Grocery store, new construction
Climate Zone	ASHRAE Zone 4A, mixed-humid
Ownership	Tenant, pays all utility bills
Barrier Addressed	How to identify the most energy efficient refrigeration and HVAC equipment options
Square Footage	40,000 ft ²
Expected Energy Savings (Versus Current New Store Specifications)	29%
Expected Energy Savings (Versus ASHRAE 90.1-2004)	41%
Expected Energy Savings (Versus ASHRAE 90.1-2004)	<ul style="list-style-type: none"> 1.4 million kilowatt-hours (kWh)/yr of electricity 15,500 therms/yr natural gas
Expected Cost Reductions (Versus ASHRAE 90.1-2004) ⁵	\$97,000/yr
Simple Payback Period	< 5 years
Expected Carbon Dioxide Emissions Avoided ⁶	1,200 metric tons/yr
Construction Completion Date	March 2011

¹ ASHRAE 90.1: <https://www.ashrae.org/resources--publications/bookstore/standard-90-1>

² CBP is a public/private, cost-shared initiative that demonstrates cost-effective, replicable ways to achieve dramatic energy savings in commercial buildings. Companies and organizations, selected through a competitive process, team with DOE and national laboratory staff who provide technical expertise to explore energy-saving ideas and strategies that are applied to specific building projects and that can be replicated across the market.

³ Available through the DOE Resource Database: http://apps1.eere.energy.gov/buildings/commercial/resource_database

⁴ EnergyPlus: <http://apps1.eere.energy.gov/buildings/energyplus/>

⁵ Using \$0.06/kWh and \$0.83/therm utility rates provided by Whole Foods Market

⁶ EPA Greenhouse Gas Equivalencies Calculator: <http://www.epa.gov/cleanenergy/energy-resources/calculator.html>

Decision Criteria

At Whole Foods Market, EEMs needed to satisfy criteria similar to those used for any investment of capital to meet the company's obligation to its shareholders. North Raleigh was selected as the location for the new construction CBP project because the company's South region volunteered to design and build a store that would cut energy use in half versus code requirements if it was economically and technically feasible.

Economic

EEMs were judged based on having a payback of 3–5 years, taking into account tax incentives, utility rebates, climate, capital costs, installation costs, operations and maintenance (O&M) costs, and energy costs. Additional economic factors included:

- Whole Foods Market pursues utility rebates where they are available and uses them to help guide where to pursue efficiency projects. Rebates were obtained from the local utility provider to help offset initial capital costs invested to lower energy use.
- Pilot funding of EEMs that do not meet the required simple payback threshold may be considered if other benefits are deemed sufficient to make the investment worthwhile. Whole Foods Market did not provide information on whether this consideration influenced the selection of EEMs for the North Raleigh project.

Branding

Environmental stewardship is a key element of the Whole Foods Market brand. EEMs installed at North Raleigh showed customers that Whole Foods Market acts in a manner consistent with its advertised image. Whole Foods Market prominently advertises its efforts to save energy in its stores.

Operational

Whole Foods Market took O&M costs into consideration when judging EEMs, both in terms of the business case for the technologies and their ability to deliver energy savings and services reliably. Whole Foods Market has developed strategies to share best practices for controlling and maintaining equipment from the North Raleigh project across the company's multiple regions. Store development leaders worked with local operations leaders to ensure EEMs would not negatively impact store operations.

Policy

Sustainability is a focus of Whole Foods Market's business practices, in terms of waste reduction, water conservation, and energy use in its stores and distribution chain. The company has had green building standards and practices in place for years. CBP was an opportunity to dig into the details of how the stores use energy and dramatically cut energy use as a result. Whole Foods Market intends to reduce energy consumed per square foot by 25% company-wide by 2015.

Whole Foods Market also maintains a policy of collecting feedback from customers to test assumptions about EEMs. For example, the company knew that putting doors on medium-temperature refrigerated display cases was a great way to save energy, but was concerned that the doors would inconvenience customers. By gathering anecdotal feedback from customers, the company found that this concern was unfounded and has installed this EEM in North Raleigh and elsewhere. Whole Foods Market also received positive feedback about using skylights to bring natural light into the sales area.

National policy issues that impact energy efficiency choices include tax policy that incentivizes efficiency investments such as the EPAct 179D federal energy tax deduction.⁷ Building codes and standards also influence the decision-making process.

Whole Foods participates in the voluntary U.S. Environmental Protection Agency's GreenChill Advanced Refrigeration Partnership⁸, which encourages food retailers to use environmentally friendlier refrigerants, reduce refrigerant charge sizes, and eliminate leaks. These efforts reduce the impact of refrigerants on the ozone layer and climate, but are typically energy neutral at best and can even increase energy use.

Energy Efficiency Measures

The table on page 3 shows the EEMs considered during the design process, all of which Whole Foods Market decided to include in the North Raleigh store. Energy savings were estimated for combined packages of EEMs affecting each end use rather than for individual EEMs. This approach allowed Whole Foods Market to account for the interaction of EEMs in terms of their energy savings and to assess whether the payback time of the combined package satisfied the company's screening criteria, even if individual EEMs appeared to be too expensive. Whole-building energy savings estimates presented in the table were calculated relative to ASHRAE 90.1-2004 and included electricity and natural gas savings. The business case for the EEM packages depended on capital costs specific to Whole Foods Market and its suppliers, which were not shared by the company. EEMs that were not applicable in all climates are marked with an asterisk (*). Climate-dependent EEMs should be evaluated to check that they are a good match for the project's climate.

⁷ DOE 179D Calculator: <http://apps1.eere.energy.gov/buildings/commercial/179d/>

⁸ EPA GreenChill Partnership: <http://www.epa.gov/greenchill>

Energy Efficiency Measures	Implemented in This Project	Will Consider for Future Projects	Expected Annual Savings	
			kWh/yr	\$/yr
Envelope: 0% Whole-Building Savings Expected Versus ASHRAE 90.1-2004				
*Add a vestibule to the store exit rather than only to the store entrance.	Yes	Yes	not modeled separately	not modeled separately
*Reduce the total glazing area and use more efficient glazing.	Yes	Yes		
Lighting: 9% Whole-Building Savings Expected Versus ASHRAE 90.1-2004				
Reduce total installed lighting down to 1 W/ft ² using a combination of linear fluorescent, metal halide, and light-emitting diodes (LEDs)	Yes	Yes	382,000	23,000
Optimize the distribution of skylights and electrical lighting fixture selection to improve controllability in response to daylight.	Yes	Yes		
Control the lighting in the dry goods section by using a bilevel strategy and reduce lighting during stocking hours.	Yes	Yes		
HVAC: 14% Whole-Building Savings Expected Versus ASHRAE 90.1-2004				
Decrease the total airflow rate throughout the sales floor from a typical 1 cfm/ft ² to 0.6 cfm/ft ² to reduce fan power consumption.	Yes	Yes	574,000	34,000
Control sales floor humidity using a main air handling unit featuring a desiccant wheel with waste heat regeneration and bypass.	Yes	Yes		
Refrigeration: 15% Whole-Building Savings Expected Versus ASHRAE 90.1-2004				
Use electronically commutated evaporator fan motors in refrigerated display cases.	Yes	Yes	628,000	38,000
Use LED fixtures instead of T-8 fluorescents in all low- and medium-temperature refrigerated cases and walk-in freezers.	Yes	Yes		
Add night curtains to open meat and produce multideck cases.	Yes	Yes		
Add doors to open medium-temperature dairy, deli, and packaged produce cases.	Yes	Yes		
Capture waste heat for air and service water heating.	Yes	Yes		
Use anti-sweat control strategies in combination with reduced sales floor dew point.	Yes	Yes		
Install electronic expansion valves and lower minimum saturated condensing temperature from 75°F to 55°F.	Yes	Yes		
*Use variable-speed fans to cool the low-temperature condensers.	Yes	Yes		
Kitchen: 5% Whole-Building Savings Expected Versus ASHRAE 90.1-2004				
Install side panels on all exhaust hoods to achieve a lower exhaust flow rate while capturing all the exhaust fumes.	Yes	Yes	277,000	17,000
Install demand ventilation sensors and controls to reduce the exhaust flow (and required make-up air) when there is no cooking.	Yes	Yes		
*Climate-dependent EEM				

Energy Use Intensities by End Use

Energy modeling was an integral part of the design process for the new North Raleigh store. Each design decision was evaluated in the context of how it impacted the simulated store performance. If savings did not reach the goal, more work was done to identify additional opportunities to extend the savings as far as possible. At the same time, modeled savings were used by the Whole Foods Market financial team to screen EEMs according to whether they met the company’s investment criteria.

For the North Raleigh store, packages of EEMs were modeled for each building system separately and then together as an integrated whole-building package to identify energy and capital cost reduction opportunities from system interactions, such as using reclaimed waste heat for space and service hot water heating.

The energy model of the proposed design was based on Whole Foods Market’s design and construction documents and information shared by the company about its occupant density, plug load diversity, real efficiency curves for HVAC systems, and other factors specific to the operation of its stores. Modeling accuracy was assessed by comparing output from an EnergyPlus model of the Whole Foods Market current specifications with utility bills from a representative store.

To assess whole-building savings for this case study, three energy models were created, as described below. The energy consumed annually by each model normalized by floor area (called energy use intensity or EUI) is shown in the graph at the bottom of the page.

By comparing models and measurements, NREL researchers identified deficiencies in how refrigeration, advanced HVAC, and kitchen exhaust systems were represented in EnergyPlus,

leading to improvements that are now available to the entire design community.

Code Baseline

The first energy model represented minimal compliance with the requirements of ASHRAE 90.1-2004 for building envelope, lighting, and mechanical systems and ASHRAE 62.1-2004 for ventilation. Additional work was done to develop a refrigeration baseline, analogous to ASHRAE 90.1-2004, to capture the impact of energy-saving innovations. The North Raleigh Whole Foods Market code baseline model had an annual EUI of about 350 kBtu/ft².


Current “Prototype”

The second model represented a Whole Foods Market built to the company’s pre-CBP new store specifications operating in North Raleigh. Whole Foods Market does not use a prototypical set of plans per se, but does maintain a set of guidelines and best practices influencing store energy use. This model was calibrated using energy data from an existing new store and then run with a weather data file representing North Raleigh’s climate. This model had an annual EUI of approximately 294 kBtu/ft², 16% below ASHRAE 90.1-2004 requirements. Savings resulted from lower lighting power density, improved envelope, and more efficient HVAC equipment than required by code.

Final Design

The third model incorporated the EEMs selected for the North Raleigh new store design. This model had an annual EUI of about 208 kBtu/ft² and an annual energy savings of 41% versus ASHRAE 90.1-2004 requirements and 29% versus the Whole Foods Market current prototype model.

Comparing Estimated EUI of Code Baseline, Current Prototype, and Final Design Energy Models



Estimated Annual Energy Use and Percentage Savings by End Use

End Use Category	Code Baseline	Current Prototype		Final Design	
	Annual EUI (kBtu/ft ²)	Annual EUI (kBtu/ft ²)	Percent Savings Versus Code Baseline	Annual EUI (kBtu/ft ²)	Percent Savings Versus Code Baseline
Heating (gas)	52	49	6	24	54
Cooling (electric)	9	6	33	5	44
Lighting (electric)	49	42	14	21	57
Equipment (electric)	54	54	0	43	20
Equipment (gas)	15	15	0	12	20
Fans (electric)	27	23	15	13	52
Refrigeration (electric)	127	91	28	81	36
Service Hot Water (gas)	17	14	18	9	47
Total	350	294	16	208	41

Expected Building Energy Savings From Selected EEMs by End Use Versus Code Baseline

Electricity End Use

Cooling	55,000 kWh/yr
Lighting	382,000 kWh/yr
Equipment	150,000 kWh/yr
Fans	191,000 kWh/yr
Refrigeration	628,000 kWh/yr
Electricity Total	1,406,000 kWh/yr

Natural Gas End Use

Heating	11,200 therms/yr
Equipment	1,200 therms/yr
Service hot water	3,100 therms/yr
Natural Gas Total	15,500 therms/yr⁹

⁹ Equivalent to 454,000 kWh

Lessons Learned

As part of the CBP work on the North Raleigh store, Whole Foods Market and DOE learned several lessons, described below, that can help other companies achieve similar results.

Carefully commission energy submeters

Meters were installed by a third-party company in the North Raleigh store to measure the electricity and gas consumption of all end uses. However, there were problems with calibration, documentation, and installation of the meters. These issues made it difficult to assess store operation until corrective measures were taken, which consumed time and resources.



Efficient equipment can lead to significant energy savings in grocery stores that offer hot prepared food items.

NREL/PIX 18615

Use performance-based procurement

To select the most efficient HVAC and refrigeration systems for the North Raleigh store, NREL staff worked with the region's engineering partners and store development team to present a request for proposals to several interested manufacturers. The request for proposals specified the loads, outdoor conditions, and space conditions the equipment would need to meet. The manufacturers responded with the cost and energy use of their products, significantly streamlining Whole Foods Market's process of identifying and procuring the most efficient options.

“We make it clear that the effort to improve energy efficiency makes sound business sense in addition to being the right thing to do.”

—Kathy Loftus,

Global leader of sustainable engineering and energy management, Whole Foods Market Corporation

Involve all players early in the process

Everyone involved in designing, building, and commissioning the building came together starting early in the design process. This move enabled the commissioning agent to provide a detailed review of the final store plans and make recommendations about the design and intended operation. Through the relationship established with the design team, the commissioning agent developed a detailed knowledge of the design and the team's intent, allowing him to catch problems during the store's commissioning that might have otherwise gone unnoticed. Measurement and verification could have benefitted from following this lesson. The measurement system should be specified as part of the store design process rather than after the fact, and the configuration of submeters should be included in the store construction documents.

Use equipment only as needed

Many companies run equipment and building systems such as lights and HVAC longer and at higher power than necessary to provide the required service. Whole Foods Market saved energy in North Raleigh by using automated controls that matched equipment function to load and that turned off or idled equipment when it was not needed. Examples included kitchen hoods, refrigeration condenser fan motors, refrigerated display case door anti-sweat heaters, and lighting. Careful inspection, calibration, and ongoing maintenance were required to ensure that potential savings in the building design translated into real energy savings.

An open and shut case

Putting doors on medium-temperature refrigerated cases, when coupled with LEDs, electronically commutated evaporator fan motors, and anti-sweat heater controls that respond to store dew point translated into major savings. Whole Foods Market also sought feedback about the doors from its customers, who responded positively to the change.