



Russell Neal, SCE

---

## NREL HIGH PENETRATION PV PROJECT AT SOUTHERN CALIFORNIA EDISON

## SCE SPVP Program Status

- SCE SPVP has 84 MW of projects completed and interconnected. One additional 7 MW rooftop in construction
- Total of 24 sites – 23 rooftops and 1 ground-mount (1 to 10 MW in size)
- One project, Dexus in Perris, is a 10 MW rooftop
  - Largest single solar rooftop in the US
  - Interconnected onto one 12 kV customer circuit.
- Future plans call for 2 additional rooftops (12 MW) and 2 ground mounts (18 MW)
- Program to complete by YE 2014

# Completed SCE SPVP Projects

SPVP 005 - PLD Redlands 1

3.39 MWdc - 10,680

Sunpower Modules

468,000 Square ft.

5 Satcon Inverters



SPVP 007 - PLD Redlands 3

3.20 MWdc - 10,840

SunPower Modules

446,000 Square ft.

5 Satcon Inverters



SPVP 042 – Porterville

6.77 MWdc - 29,428

Trina Modules

33 acres

10 Satcon Inverters



# Completed SCE SPVP Projects

SPVP 006 - PLD Ontario 2

2.55 MWdc

11,088 Trina Modules

562,000 Square ft.

4 Satcon Inverters



SPVP 008 - PLD Ontario 4

2.85 MWdc

12,376 Trina Modules

681,000 Square ft.

4 Satcon Inverters



SPVP 009 - PLD Ontario 3

1.41 MWdc

8,131 Trina Modules

369,000 Square ft.

2 Satcon Inverters



SPVP 012 - PLD Ontario 5

.77 MWdc

3,360 Trina Modules

241,000 Square ft.


1 Satcon Inverter



# NREL Project

- Study impacts and mitigations
- Combined DOE and CPUC/CSI funding
- Model three circuits with SPVP impacts
- Develop active inverter mitigations
- Field test and measurements
- Guidebook for deploying HPPV on distribution circuits

# Approach and Tasks



# State of the Project

- Circuits selected
  - > Fontana 12 kV, 3.5 MW PV
  - > Porterville 12kV, 5 MW PV
  - > Palmdale 12 kV, 3 MW PV (3<sup>rd</sup> party)
- Supplemental instruments being deployed
- Inverter modification options investigated
  - > Issue: Satcon bankruptcy
  - > Alternatives: PF switching, Other controls

# Thank You!

[Russell.Neal@sce.com](mailto:Russell.Neal@sce.com)  
[George.Rodriguez@sce.com](mailto:George.Rodriguez@sce.com)





Barry Mather Ph.D., NREL

---

# MODELING, SIMULATION, TESTING AND DEMONSTRATION OF A 500KW COMMERCIAL ROOF-TOP PV SYSTEM ON SCE'S DISTRIBUTION SYSTEM

# Project Sponsors and Team Members

## Project Sponsors:



Energy Efficiency &  
Renewable Energy

## Project Team Members:



High  
Penetration

Feb 13-14, San Diego, CA

2013

# Focus Areas

- Distribution system modeling and simulation for high-penetration PV scenarios
- Identifying the effects of high-penetration PV and developing methods to mitigate these effects
- Advanced inverter functionality development and testing
- High-penetration PV demonstration


# Key Project Deliverables and Activities

- Modeling of High-Penetration PV Distribution Circuits (x3)
  - > Report on Methods for Hi-Pen PV Integration Studies
  - > Report on Recommended Mitigation Methods for Hi-Pen Circuits
  - > Verification of Circuit Models/PV Impacts Using Collected Data
  - > Report on Quasi-Static Time-Series Modeling for Hi-Pen PV
- Demonstration of Advanced PV Inverter Functionality to Mitigate PV Impacts
  - > Development of Advanced Functionality Specifications
  - > Laboratory Testing of Adv. PV Inverters
  - > Demonstration of Adv. PV Inverters in SCE system

# Key Project Deliverables and Activities Cont.


- Publish a Handbook on Distribution Interconnected High-Penetration PV Integration

# Fontana, CA Study Circuit




- 12 kV circuit, 7.8 miles, commercial/warehouse loads
- PV AC rating: 4.5 MW, reverse power flow conditions possible
- Circuit voltage regulation by switched capacitors

# Fontana, CA Study Circuit – Circuit Power Flow




Jan 3<sup>rd</sup>, 2013

# Fontana, CA Study Circuit – Substation Power Flow



- Reverse power flow through the “express” part of the circuit is likely common on clear shoulder season days


# Porterville, CA Study Circuit



- 12 kV circuit,  
47.2 miles, rural,  
lightly loaded/  
water pumping  
loads
- PV AC rating: 5  
MW
- Reverse power  
flow common
- Voltage  
regulation via  
switched  
capacitor banks

# Palmdale, CA Study Circuit

- 12kV circuit, less than 5 miles of total circuit length, very lightly loaded, nearly an “express circuit”
- PV AC rating: 3 MW
- Reverse power flow conditions present during daylight hours (when clear)
- Current voltage regulation issues may prompt operating the PV inverters at a lagging power factor




# 500kW PV Inverter Testing – Collaboration




- The SCE Hi-Pen PV Integration Project teamed with FSU CAPS – SUNGRIN Team to complete this Power Hardware-in-Loop (PHIL) evaluation of a 500kW Satcon PV Inverter operating in advanced functionality modes


# 500kW PV Inverter Testing - Setup



PV Profiles




Fontana Study Circuit




- Each testing period consisted of 16 minute long evaluations of the PV inverter realizing advanced functionality (non-unity PF operation and constant VAr operation) as if the inverter were connected to the Fontana, CA Study Circuit

# 500kW PV Inverter Testing - Results




PV inverter power output  
for various PF set points




P-Q plot of PV inverter output  
for various PF set points

- Conclusion: the PV inverter tracked a PF set point very well over highly variable solar resource profiles.

# 500kW PV Inverter Testing - Results




PV inverter real and reactive power output for various PF set points



P-Q plot of PV inverter output for various PF set points



- Conclusion: the PV inverter tracked a constant VAr set point very well over highly variable solar resource profiles. Some modifications to “foldback” algorithm need to be addressed

# 500kW PV Inverter Testing - Results



- Fontana, CA circuit model, 2MW PV system consisting of 4 x 500kW Satcon PowerGate Plus Inverters
- Results shown for “high-variability” resource
- Constant PF operation at 0.95 lagging reduces voltage profile impact due to PV

# Comparison: Time-Series vs. Transient Simulations



- Tests Quasi-Static Time-Series Analysis at multiple time steps
- Follow-on study is being completed for volt/VAr controls

		PSCAD	OpenDSS						
			5s	10s	15s	30s	40s	50s	
Load tap changer	Reg. #3	Max	5	6	5	5	6	5	
		Min	4	5	5	5	5	5	
		# of actions	1	1	0	0	1	0	
Reg. #3	A	Max	7	6	6	6	6	7	
		Min	4	3	3	3	4	4	
		# of actions	7	6	7	5	8	2	
Reg. #3	B	Max	4	4	4	4	4	4	
		Min	1	2	1	1	2	1	
		# of actions	8	5	6	5	6	2	
Reg. #3	C	Max	2	2	1	1	1	1	
		Min	-1	-1	-1	-1	-1	0	
		# of actions	8	6	6	4	8	1	
Cap. #1		Opening time (s)	489	495	-	-	470	-	
							150		

Please contact:

Barry Mather – [barry.mather@nrel.gov](mailto:barry.mather@nrel.gov) (303)-275-4378

---

## Q & A AND DISCUSSION

---

# THANK YOU