

# Solar Power Tower R&D

May 24-27, 2010  
Washington D.C.

This presentation does not contain any proprietary, confidential, or otherwise restricted information

CSP: Tower R&D

**Gregory J. Kolb**

Sandia National Laboratories  
[gjkolb@sandia.gov](mailto:gjkolb@sandia.gov) (505) 844-1887

Date: May 26, 2010

## Timeline

- Start: October 1<sup>st</sup> , 2009
  - End: Ongoing program activity
- Power Tower R&D is now an official R&D Agreement at DOE after a several year absence*

## Budget

- FY10 budget is \$1050K
  - 760 K received so far
- FY09 budget was \$233K  
(conducted as a task within CSP Advanced Concepts R&D Agreement)

## Barriers


- Barriers addressed
  - Technology Risk
  - Capital Cost Reduction
  - Improved Performance

## Partners



- Interactions/ collaborations
  - Power Tower Industry
    - Solar Reserve/Rocketdyne
    - Brightsource
    - eSolar
    - SENER
    - Abengoa
  - DLR (German Nat'l Lab)

# Accomplishments Reported at 2009 Peer Review

- 1-mile heliostat test
  - SolarReserve
- Steam receiver model upgrade
  - eSolar, Brightsource, Abengoa



- Performance modeling software training/intercomparison
  - Rocketdyne and eSolar
- Solid-particle receiver test
  - H<sub>2</sub> production and Hi-T power cycles



- Resurrection of steam receiver technology
  - PS-10 MW<sub>e</sub> on grid 6/07, PS-20 5/09 (Abengoa)
  - 5 MW<sub>e</sub>, 2-tower plant on utility grid 7/09 (eSolar)
  - 5 MW<sub>t</sub> thermal-only demonstration since late 08 (Brightsource)
  - Lessons learned from 10 MW<sub>e</sub> Solar One, shutdown in 1988
  - Steam receivers perceived as “low risk,” many PPA’s announced



eSolar





Brightsource



Abengoa

- SENER 17 MW<sub>e</sub> Gemsolar project now under construction
  - 2650 heliostats, 116 m<sup>2</sup> each
  - 120 MW<sub>t</sub> receiver (3X scaleup from Solar Two), 140 m tower
  - 15 hrs of storage (6X scaleup)
  - Startup in 2011 (Torresol)
- Solar Reserve's receiver is 540 MW<sub>t</sub>
  - PPAs announced



## R&D Tasks

### 1. Power Tower Plant Analysis

- Develop Tower R&D Roadmap
- Analysis of next generation power towers
- Software tool development and industry training

### 2. Heliostat Analysis

- New CAD models to include gravity and wind effects on performance
- Develop tracking software with self correcting features to achieve <1mrad tracking accuracy

### 3. Advanced Heliostat Development

- Support testing and performance optimization of industry heliostats
- Design reviews and field performance tools
- Rapid alignment tools

- Financial risk of new tower plants perceived to be high
  - Only 35 MW of commercial towers now operating
  - Sandia is performing tests and evaluations with industry to reduce risk
  - Near-term R&D
- Heliostat cost and performance dominate economics of tower plants
  - Heliostats account for ~50% of tower plant capital cost
  - Each power tower company is developing their own heliostat, each having their own advantages and disadvantages
  - Near-term R&D
- Tower plant heat-to-electricity efficiency can be improved
  - Increase from 42% to 48% (Mid-term R&D)
  - Eventually increase to >50% conversion efficiency (Long-term R&D)

## Technical Accomplishments Since Last Peer Review

- Task 1: Power Tower Analysis
- Task 2: Heliostat Analysis
- Task 3: Advanced Heliostat Development



## Tower Roadmap

Power Tower Road Map meeting conducted at Sandia's NSTTF March 24 and 25, 2010.


Purpose: to start development of a technology road map to accelerate the commercial deployment of Power Towers.

- address technology development issues,
- reduce the cost of Power Tower systems and components, and
- discuss non-technical issues that could accelerate deployment.

DOE will use the Power Tower roadmap to

- evaluate current projects,
- identify new Funding Opportunity topics,
- advise laboratory research,
- guide DOE CSP budget requests, and
- support the development of DOE's next Program Plan for the Solar Energy Technology Program.





## ROADMAP ATTENDEES

SENER Eng, San Francisco, CA

BrightSource Energy, Inc.,

SolarReserve, Santa Monica, CA

Worley Parsons, Golden, CO 80401

Black&Veatch Overland Park, KS

Rocketdyne, Canoga Park CA

eSolar. Pasadena, CA

Abengoa Solar, Denver, CO.

Sargent & Lundy, Chicago, IL

EPRI, Albuquerque, NM

NREL, Golden, CO

DOE HQ, Washington, DC

Sandia Nat. Labs. Albuquerque, NM

## Roadmap Process and Schedule

- |   |  |
|---|--|
| a) <i>Determine baseline and goals for component costs and performance,</i> | <b><i>Preliminary evaluation with ongoing analysis.</i></b>    |
| b) <i>Identify technology improvement opportunities (TIOs),</i>             | <b><i>Preliminary evaluation with ongoing analysis.</i></b>    |
| c) <i>Assess and prioritize TIOs,</i>                                       | <b><i>Preliminary evaluation with ongoing analysis.</i></b>    |
| d) <i>Develop a draft Power Tower Road Map for review by industry, and</i>  | <b><i>Draft available in mid June 2010.</i></b>                |
| e) <i>Publish final Power Tower Road Map.</i>                               | <b><i>Final draft scheduled by late July early August.</i></b> |

## Roadmap Baseline Subsystem Costs and Plausible Goals

	Solar Field	Solar Receiver	Thermal Storage	Power Block	Steam Generation	O&M
Baseline (prelim.)	\$200/m <sup>2</sup>	\$200/kW	\$30/kWh <sub>t</sub>	\$1000/kW	\$280-350/kW <sub>e</sub>	\$65/kW <sub>yr</sub>
Plausible Goal	\$120/m <sup>2</sup>	\$170/kW	\$20/kWh <sub>t</sub>	\$800/kW <sub>e</sub>	\$250/kW <sub>e</sub>	\$50/kW <sub>yr</sub>


## Roadmap Technology Improvement Opportunities (TIO)

Solar Field	Solar Receiver	Thermal Storage	Power Block/Balance of Plant
<ul style="list-style-type: none"> <li>- Drives and controls</li> <li>- Impact of wind loads</li> <li>- Anti-fouling/cleaning of glass</li> <li>- Need for a manufacturing funding opportunity announcement (FOA)</li> <li>- Optical testing of a complete assembly</li> <li>- Optimization of structure, facet, etc.</li> </ul>	<ul style="list-style-type: none"> <li>- Receiver materials testing data base</li> <li>- Selective absorbers</li> <li>- High temperature receivers (600-700°C)</li> <li>- Tall tower acceptance</li> <li>- Flux measurements</li> <li>- Hybrid and steam receivers</li> <li>- Receiver thermal loss measurement and mitigation</li> </ul>	<ul style="list-style-type: none"> <li>- High temperature storage (alternative fluids, containment, single-tank ratcheting, etc.)</li> <li>- Valves and non-welded flanges</li> <li>- Hybridization system study</li> <li>- Solid storage for steam</li> <li>- Education: value of storage</li> <li>- Phase change material</li> </ul>	<ul style="list-style-type: none"> <li>- Low water use cooling</li> <li>- (Ultra) supercritical steam cycles</li> <li>- Supercritical CO<sub>2</sub> / advanced power cycles</li> <li>- High efficiency hybrid configurations</li> <li>- Designs for rapid temperature changes</li> <li>- Reduction of parasitic loads</li> </ul>


*Sandia's initial evaluation of Roadmap cost goals suggest that Tower LCOE can be reduced by >40%*

- Tower vs. Trough analysis conducted by Sandia/NREL and presented to DOE in February 2010
  - First side-by-side comparison since Sargent and Lundy study
  - Sandia/NREL concluded that original Sargent and Lundy economic comparison has not changed significantly (in a relative sense)
  - New investigation at near “base-load” capacity factors (70%) concluded that tower LCOE should be ~35% lower than troughs in the near term
    - 13 to 15 hrs of storage is needed for base load
    - Storage cost for towers is nominally 3X lower than troughs
    - Tower capacity factor is more uniform throughout the year than troughs

In a molten salt power tower, LEC is reduced by adding up to 13 hours of storage




**Power Tower LEC is reduced up to 25% for a given power block  
by adding storage and increasing the solar field size  
to increase plant capacity factor**







- Next generation tower study is underway
  - Raise salt temperature from 565 °C to 650 °C
    - Increase Rankine efficiency from 42% to 48%
    - Reduce storage cost by increasing  $\Delta T$




IPSEpro Model  
By DLR

**48% Rankine  $\eta$  at full power     $\Delta T$  increased 24% at full power**




- Initial CAD model of NSTTF heliostat completed
  - SolidWorks finite-element model
  - CosmosWorks analysis of wind and gravity
  - ASAP ray-trace optics model
  - Methodology developed by CSP Advanced Concepts Agreement




- Initial error-correcting heliostat tracking software developed
  - Compensates for heliostat manufacturing and installation errors such as pedestal tilt, non-orthogonal structure, encoder offsets
  - Technique first described by Baheti & Scott (1980) with modifications by recent Stirling Dish R&D

## Heliostat Tracking Error Sources



- Supported the installation of Rocketdyne heliostats at NSTTF
  - 62 m<sup>2</sup> heliostat
  - 1<sup>st</sup> generation heliostat test completed
  - Three 2<sup>nd</sup> generation units now being installed
- Total field flux mapping tool under development
  - Moving wand
  - Stitching software



<b>Milestones</b>	<b>Task #</b>	<b>Date</b>
1. Provide analysis training to 3 or more organizations from US industry	1	8/31/10
2. Complete draft of SAND report summarizing system analysis of new power tower concepts capable of $\geq 650^{\circ}\text{C}$	1	9/30/10
3. Complete CAD models of NSTTF heliostats	2	2/18/10
4. Validate models of heliostats	2	9/30/10
5. Complete initial development of heliostat flux characterization tool	3	7/31/10
6. Develop initial heliostat slope-error and alignment methods	3	9/30/10

- Expand R&D collaboration with power tower companies to reduce technical risk of 1<sup>st</sup> commercial projects
  - During design phase
  - During startup, test, and evaluation phases
- Develop and implement an R&D plan for the labs that address the TIO's identified in the March 2010 Roadmap Meeting
- Perform analysis and test prototype hardware to support development of next-generation power towers
  - Raise operating temperature from today's 565 °C, to 650 °C and beyond
  - Improve thermal conversion efficiency from today's 42% to 48% and beyond

- After a several year lapse, Power Tower R&D is once again a principal agreement within the DOE solar program
- Commercial interest in power towers is growing strong and DOE R&D funding was increased by a factor of 5 in 2010
- 5 commercial tower companies came together for the first time at Sandia to help develop a technology Roadmap
- Heliostat issues dominate the cost and performance of power tower projects and most of the DOE program is devoted to heliostats
- If towers can surpass financial/technical risk hurdles, they are predicted to achieve lower LCOEs than troughs, especially for plants with near base-load capacity factors
- The technology to support next-generation towers (650 °C, 48% efficient) is very plausible and within reach