



Online PM Measurement for In-use Testing

The Modern Diesel Aerosol and its measurement and correlation to lab reference PM using the MSS 483 Microsoot sensor with SOF and sulfate compensation.

Poster Location P-16

Michael Arndt, Wolfgang Schindler and William Silvis

AVL Instrumentation and Test Systems, Inc.

4 August 2009

Photo-acoustic PM instrument mounted for in-use measurements



Mass:

§ The photo acoustic measurement principle is soot mass based.

Total PM:

§ The Micro Soot Sensor gives total PM by measuring the major soot component and compensating for the rest.

3 Truck Correlation

